

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

See Instructions on Reverse Side

Sec 27 T9N4W

1. County Crawford

Town
Village
City

Barnum
Check one and

RECEIVED
APR 13 1954

2. Location Barnum, Wisconsin
Name of street and number of premise or Section, Town and Range numbers

3. Owner or Agent Barnum School
Name of individual, partnership or firm

ENVIRONMENTAL
SANITATION

4. Mail Address Barnum, Wisconsin
Complete address required

School

5. From well to nearest: Building 50 ft; sewer 0 ft; drain 0 ft; septic tank 0 ft;
dry well or filter bed 0 ft; abandoned well 70 ft.

6. Well is intended to supply water for: School

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	17	6	17	120

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	standard	0	70

9. GROUT:

Kind	From (ft.)	To (ft.)
sand and clay	0	17

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
mixed clay + rock	0	17
sand, fine	17	70
shale, stone	70	115
sand stone	115	120

11. MISCELLANEOUS DATA:

Yield test: _____ Hrs. at _____ GPM.
 Depth from surface to water-level: 20 ft.
 Water-level when pumping: 20 ft.
 Water sample was sent to the state laboratory at:
Madison on April 5 1954
City

Construction of the well was completed on:

April 1 1954

The well is terminated 6 inches
 above, below the permanent ground surface.

Was the well disinfected upon completion?

Yes No _____

Was the well sealed watertight upon completion?

Yes No _____

Signature Kenneth Coplan
Registered Well Driller

Boscobel, Wisconsin
Complete Mail Address

Please do not write in space below

Rec'd APR 6 1954 No. 6580

Ans'd _____
Interpretation **SAFE**

10 ml 10 ml 10 ml 10 ml 10 ml

Gas—24 hrs. 0

48 hrs. 0

Confirm _____

B. Coli _____

0/5 Examiner _____