

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

Vol 6

See Instructions on Reverse Side

1. County Crawford Town  Naney  
 Village   
 City  Check one and give name

2. Location Section 31 T9N R4W  
 Name of street and number of premise or Section, Town and Range numbers

3. Owner  or Agent  Kenneth Crowley  
 Name of individual, partnership or firm

4. Mail Address R 7 D Steuben, Wis.  
 Complete address required

5. From well to nearest: Building 8 ft; sewer 30 ft; drain 30 ft; septic tank 55 ft;  
 dry well or filter bed 75 ft; abandoned well 100 ft.

6. Well is intended to supply water for: farm home

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	45	6	45	110

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6"	standard wt	0	45

9. GROUT:

Kind	From (ft.)	To (ft.)
Clay	0	30
Cement	30	45

11. MISCELLANEOUS DATA:

Yield test: 12 Hrs. at 8 GPM.  
 Depth from surface to water-level: 90 ft.  
 Water-level when pumping: 90 ft.  
 Water sample was sent to the state laboratory at:  
Madison on 5-15 1962  
 City

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
top soil	0	5
Clay	5	25
limestone	25	80
sandstone	80	110

RECEIVED

MAY 22 1962

Sanitary ENGINEERING

Construction of the well was completed on:  
April 25 1962

The well is terminated 10 inches  
 above, below  the permanent ground surface.

Was the well disinfected upon completion?  
 Yes  No

Was the well sealed watertight upon completion?  
 Yes  No

Signature Kenneth Crowley  
 Registered Well Driller

R 3 Box 36, Boeschee  
 Complete Mail Address Wis.

Please do not write in space below

Rec'd MAY 16 1962 No. 14886

Ans'd \_\_\_\_\_

Interpretation SAFE—BACTERIOLOGICALLY

	10 ml	10 ml	10 ml	10 ml	10 ml
Gas—24 hrs.					
48 hrs.					
Confirm					
B. Coli					

Examiner \_\_\_\_\_