

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH  
See Instructions on Reverse Side

1. County Crawford Town  Haney  
Village   
City  Check one and give name

2. Location Section 31 (9N, R4W)  
Name of street and number of premise or Section, Town and Range numbers

3. Owner  or Agent  Robert Zinkle  
Name of individual, partnership or firm

4. Mail Address R.F.D. 1 Steubens, Wisconsin  
Complete address required

5. From well to nearest: Building 6 ft; sewer 25 ft; drain 25 ft; septic tank 75 ft;  
dry well or filter bed 100 ft; abandoned well 50 ft.

6. Well is intended to supply water for: farm + home

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	44	6	44	90

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6"	standard wt	0	44

9. GROUT:

Kind	From (ft.)	To (ft.)
Clay	0	30
Cement	30	44

11. MISCELLANEOUS DATA:

Yield test: 5 Hrs. at 15 GPM.  
Depth from surface to water-level: 40 ft.  
Water-level when pumping: 40 ft.  
Water sample was sent to the state laboratory at:  
Madison on Sept. 22 1959  
City

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
Clay	0	30
limestone	30	65
shalestone	65	90

Construction of the well was completed on:  
May 27 1959

The well is terminated 10 inches  
 above, below  the permanent ground surface.

Was the well disinfected upon completion?  
Yes  No

Was the well sealed watertight upon completion?  
Yes  No

Signature Kenneth Coplan  
Registered Well Driller

R3, Box 36 Boscobel, Wis  
Complete Mail Address

Please do not write in space below

Rec'd SEP 23 1959 33706

Ans'd \_\_\_\_\_  
Interpretation **SAFE**

10 ml 10 ml 10 ml 10 ml 10 ml  
Gas—24 hrs. \_\_\_\_\_  
48 hrs. \_\_\_\_\_  
Confirm \_\_\_\_\_  
B. Coli 0

Examiner \_\_\_\_\_