

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

OCT 3 1975

1. COUNTY Crawford CHECK ONE Town Village City NAME Haney

2. LOCATION - 1/4 Section SW Section 33 Township 9N Range 4W 3. OWNER AT TIME OF DRILLING Lawrence Bay
OR - Grid or street no. Street name ADDRESS RFD

AND - If available subdivision name, lot & block no. POST OFFICE Stephens Wis. 54657

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER C. I.	SEWER TILE	FLOOR DRAIN C. I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
<u>15'</u>	<u>100'</u>		<u>100'</u>					

CLEAR WATER DRAIN C. I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>150'</u>			<u>170'</u>	<u>300'</u>	<u>350'</u>	<u>50'</u>	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>71</u>	<u>6</u>	<u>71</u>	<u>100</u>	<u>Clay</u>	<u>Surface</u>	<u>45</u>
						<u>soft sandstone</u>	<u>45</u>	<u>55</u>
						<u>hard shalestone</u>	<u>55</u>	<u>100</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>71</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>puddled clay</u>	<u>Surface</u>	<u>45</u>
<u>Cement</u>	<u>45</u>	<u>71</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 9-6-1975

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 5 GPM

Well is terminated 8 inches above below final grade

Depth from surface to normal water level 60 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 68 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9-29-1975

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel Wis. 53805
R3 Box 84

COLIFORM TEST RESULT 761 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS
 REV. 3-71