

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Haney

2. LOCATION SE 34 9N 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
Royal Jenkins
 ADDRESS R1
 POST OFFICE Sage Mills, Wis., 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) 100'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer		C.I.	Other							Seepage Pit	
				Clearwater Dr.										Seepage Bed	
														Seepage Trench	

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank

Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>65</u>	<u>6</u>	<u>65</u>	<u>100</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel R.E. 18.97 A-53</u>	<u>Surface</u>	<u>65</u>
	<u>Valley Steel Pitless adapter</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>65</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>15</u>
<u>loose stone & clay</u>	<u>15</u>	<u>45</u>
<u>hard shale stone</u>	<u>45</u>	<u>60</u>
<u>sandstone</u>	<u>60</u>	<u>100</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 10-27-1979

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Well is terminated 12 inches above final grade below

Depth from surface to normal water level 50 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 72 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 11-13-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address Boscobel, Wis., R2 Box 4 53805

7666