

JUN 3 1976

NOTE:
 White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

| | | | | | | | | | | |
|--|--|--|---|--|--|---|---------------------------------------|--|--------------|--------------------------------------|
| 1. COUNTY <u>Crawford</u> | | CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City | | | Name <u>Haney</u> | | | | | |
| 2. LOCATION 1/4 Section <u>NE</u> Section <u>34</u> Township <u>9N</u> Range <u>4W</u> | | 3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Harley Dalton</u> | | | ADDRESS <u>RFD 2</u> | | | | | |
| OR - Grid or Street No. Street Name | | POST OFFICE <u>Gays Mills, Wis., 54631</u> | | | AND - If available subdivision name, lot & block No. | | | | | |
| 4. Distance in feet from well to nearest: (Record answer in appropriate block) | | Building <u>30'</u> | Sanitary Bldg. Drain C.I. <u>40'</u> Other | Sanitary Bldg. Sewer C.I. Other | Floor/Drain Connected To: C.I. Sewer Other Sewer | Storm Bldg. Drain C.I. Other | Storm Bldg. Sewer C.I. Other | | | |
| Street Sewer San. Storm | Other Sewers C.I. Other | Foundation Drain Connected to: Sewer Clearwater Dr. | Sewage Sump Sewage Sump Clearwater Sump | Sewage Sump C.I. Other | Clearwater Sump | Septic Tank <u>70'</u> | Holding Tank | Sewage Absorption Unit Seepage Pit <u>80 ft.</u> Seepage Bed Seepage Trench | | |
| Privy | Pet Waste Pit | Pit: Nonconforming Existing Well Pump Tank | Subsurface Pumphouse Nonconforming Existing | Barn Gutter | Animal Barn Pen | Animal Yard | Silo With Pit | Glass Lined Storage Facility | Silo w/o Pit | Earthen Silage Storage Trench Or Pit |
| Temporary Manure Stack | Watertight Liquid Manure Tank | Solid Manure Storage Structure | Subsurface Gasoline or Oil Tank | Waste Pond or Land Disposal Unit (Specify Type) | Other (Give Description) | | | | | |
| 5. Well is intended to supply water for: <u>Trailer home</u> | | | | | 9. FORMATIONS | | | | | |
| 6. DRILLHOLE | | | | | Kind | From (ft.) | To (ft.) | | | |
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | | | | | |
| <u>10</u> | <u>Surface</u> | <u>44</u> | <u>6</u> | <u>44</u> | <u>100</u> | <u>Clay</u> | <u>Surface</u> <u>15</u> | | | |
| | | | | | | <u>broken limestone</u> | <u>15</u> <u>35</u> | | | |
| | | | | | | <u>hard shalestone</u> | <u>35</u> <u>100</u> | | | |
| 7. CASING, LINER, CURBING AND SCREEN | | | | | 10. TYPE OF DRILLING MACHINE USED | | | | | |
| Material, Weight, Specification & Method of Assembly | | | | | <input type="checkbox"/> Cable Tool | <input type="checkbox"/> Rotary-hammer w/drilling mud & air | <input type="checkbox"/> Jetting with | | | |
| Dia. (in.) | | | From (ft.) | To (ft.) | <input type="checkbox"/> Rotary-air w/drilling mud | <input checked="" type="checkbox"/> Rotary-hammer & air | <input type="checkbox"/> Air | | | |
| <u>6</u> | <u>new black steel plain end 18.97</u> | | <u>Surface</u> | <u>44</u> | <input type="checkbox"/> Rotary-w/drilling mud | <input type="checkbox"/> Reverse Rotary | <input type="checkbox"/> Water | | | |
| | <u>A-53</u> | | | | | | | | | |
| | <u>Valley Steel</u> | | | | | | | | | |
| 8. GROUT OR OTHER SEALING MATERIAL | | | | | Well construction completed on <u>5-13-</u> 19 <u>76</u> | | | | | |
| Kind | | From (ft.) | To (ft.) | | | | | | | |
| <u>Clay</u> | | <u>Surface</u> | <u>2</u> | | | | | | | |
| <u>Cement</u> | | <u>2</u> | <u>44</u> | | | | | | | |
| 11. MISCELLANEOUS DATA | | | | | Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade | | | | | |
| Yield Test: <u>3</u> Hrs. at <u>8</u> GPM | | Depth from surface to normal water level <u>60</u> Ft. | | Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | | | | | |
| Depth of water level when pumping <u>68</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | | | Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | | | | | |
| Water sample sent to <u>Madison</u> laboratory on <u>6-1-</u> 19 <u>76</u> | | | | | | | | | | |

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Caplan Registered Well Driller Complete Mail Address Boasabel, R3 Box 84 Wis., 53805