

FEB 4 1977

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY <i>Crawford</i>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <i>Seneca</i>	
2. LOCATION OR - Grid or Street No. Street Name		1/4 Section <i>SE</i>	Section <i>3</i>	Township <i>9N</i>	Range <i>5W</i>	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <i>Don Morovits</i>
AND - If available subdivision name, lot & block No.		ADDRESS <i>RFD</i>				
		POST OFFICE <i>Lays Mills, WI 54631</i>				
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <i>25'</i>	Sanitary Bldg. Drain C.I. Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer	Storm Bldg. Drain C.I. Other
		Foundation Drain Connected to: Sewer Clearwater Dr.	Sewage Sump C.I. Other	Clearwater Sump	Septic Tank <i>60</i>	Holding Tank
		Sewage Absorption Unit <i>75</i>				
		Sewage Pit				
		Sewage Bed				
		Sewage Trench				
Privy		Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing
		Barn Gutter		Animal Barn Pen		Animal Yard
		Silo With Pit		Glass Lined Storage Facility		Silo w/o Pit
		Earthen Silage Storage Trench Or Pit				
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank
		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)		
5. Well is intended to supply water for: <i>Country Home</i>		9. FORMATIONS				
6. DRILLHOLE		Kind		From (ft.)	To (ft.)	
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	
<i>10</i>	<i>0</i> Surface	<i>280</i>	<i>6</i>	<i>280</i>	<i>330</i>	<i>Limestone</i> Surface <i>80</i>
						<i>Sandstone</i> <i>80</i> <i>120</i>
						<i>Limestone</i> <i>120</i> <i>330</i>
7. CASING, LINER, CURBING AND SCREEN		Material, Weight, Specification & Method of Assembly		From (ft.)	To (ft.)	
Dia. (in.)						
<i>6</i>	<i>P.E. New Black Steel</i> <i>18.97</i>	<i>0</i> Surface	<i>280</i>			
	<i>Valley Steel</i> <i>A-53</i>					
	<i>Pitless Adaptor</i>					
8. GROUT OR OTHER SEALING MATERIAL		Kind		From (ft.)	To (ft.)	
		<i>Clay</i>	<i>0</i> Surface	<i>8</i>		
		<i>Cement</i>	<i>8</i>	<i>280</i>		
10. TYPE OF DRILLING MACHINE USED						
<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air		<input type="checkbox"/> Jetting with		
<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air		<input type="checkbox"/> Air		
<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary		<input type="checkbox"/> Water		
11. MISCELLANEOUS DATA		Well construction completed on <i>Jan. 11</i> 1977				
Yield Test: <i>5</i> Hrs at <i>4</i> GPM		Well is terminated <i>10</i> inches		<input checked="" type="checkbox"/> above final grade		
Depth from surface to normal water level <i>240</i> Ft.		Well disinfected upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <i>270</i> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <i>Madison</i>		laboratory on <i>Jan 31</i> 1977				

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature
Kenneth Coplan Registered Well Driller

Complete Mail Address
R3, Box 84 - Boscobel, WI