

| | | | | | | | | |
|--|---------------------|--|------------------------|----------------------|-------------------------------------|----------------------------|----------------|-----------|
| 1. COUNTY CRAWFORD | | CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City | | NAME SENECA | | | | |
| 2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.) N. 1/2 of N.E. 1/4 of SEC. 3- TWN. 9- R. 5W. | | | | | | | | |
| 3. OWNER AT TIME OF DRILLING CARL ASPERSON | | | | | | | | |
| 4. OWNER'S COMPLETE MAIL ADDRESS GAYS MILLS, WIS. 54631 | | | | | | | | |
| 5. Distance in feet from well to nearest: (Record answer in appropriate block) | | BUILDING C. I. | SANITARY SEWER TILE | FLOOR DRAIN C. I. | FOUNDATION DRAIN SEWER CONNECTED | WASTE WATER DRAIN C. I. | | |
| | | 20' | | | | | | |
| CLEAR WATER DRAIN C. I. | SEPTIC TANK TILE | PRIVY | SEEPAGE PIT | ABSORPTION FIELD | BARN | SILO | ABANDONED WELL | SINK HOLE |
| | 50' | none | 150' | 300' | 100' | none | none | none |
| OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) BARN IS A NEW GRADE A MILKING BARN. COW YARD IS BELOW THE BARN | | | | | | | | |

6. Well is intended to supply water for:
HOUSE AND DAIRY BARN.

| 7. DRILLHOLE | | | | | | 10. FORMATIONS | | |
|---------------------------------------|---------------------|----------|------------|------------|----------|---|------------|----------|
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) |
| 10" | Surface | 110' | | | | TOP SOIL | Surface | 3 |
| | | | | | | FLINT CLAY AND L imestone | 3 | 60 |
| 8. CASING, LINER, CURBING, AND SCREEN | | | | | | BROWN LIME STONE | 60' | 75 |
| Dia. (in.) | Kind and Weight | | From (ft.) | To (ft.) | | GREY LIME STONE | 75 | 110 |
| 6" | STEEL STANDARD PIPE | | Surface | 110' | | | | |
| | 19.45 PLAIN END | | | | | | | |
| | | | | | | WELL IS 287' DEEP | | |
| 9. GROUT OR OTHER SEALING MATERIAL | | | | | | | | |
| Kind | | | From (ft.) | To (ft.) | | | | |
| NEAT CEMENT | | | Surface | 110' | | | | |

| | | | | | | | | |
|--|-----|---------|----|-----|--|---|---|---|
| 11. MISCELLANEOUS DATA | | | | | | Well construction completed on NOV. 18 1968 | | |
| Yield test: | 4 | Hrs. at | 10 | GPM | | Well is terminated | 14 | inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade |
| Depth from surface to normal water level | 237 | ft. | | | | Well disinfected upon completion | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| Depth to water level when pumping | 240 | ft. | | | | Well sealed watertight upon completion | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| Water sample sent to MADISON | | | | | | laboratory on: NOV. 26 1968 | | |

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

| | | |
|--|--|--|
| SIGNATURE LEWIS HARRIS <i>Lewis Harris</i> - Registered Well Driller | | COMPLETE MAIL ADDRESS 327 N. MAIN ST. PRAIRIE DU CHIEN, WIS |
|--|--|--|

Please do not write in space below

| | | | | |
|-----------------------------|---------------|---------------|-----------|---------|
| COLIFORM TEST RESULT 771 | GAS - 24 HRS. | GAS - 48 HRS. | CONFIRMED | REMARKS |
|-----------------------------|---------------|---------------|-----------|---------|

WGNHS ORIGINAL