

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

NOV 5 1971

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Seneca

2. LOCATION - 1/4 Section SE Section 13 Township 9N Range 5W 3. OWNER AT TIME OF DRILLING Herbert Schreck

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Gays Mills, Wis. 54631

4. Distance in feet from well to nearest:

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
<u>15'</u>	<u>25'</u>	<u>25'</u>				<u>30'</u>

(Record answer in appropriate block)

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>150'</u>		<u>175'</u>		<u>200'</u>	<u>200'</u>		

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>252</u>	<u>6</u>	<u>252</u>	<u>360</u>	<u>Clay</u>	<u>Surface</u>	<u>18</u>
						<u>soft sandstone</u>	<u>18</u>	<u>130</u>
						<u>shalestone</u>	<u>130</u>	<u>160</u>
						<u>sandstone</u>	<u>160</u>	<u>220</u>
						<u>Clay</u>	<u>220</u>	<u>240</u>
						<u>sandstone</u>	<u>240</u>	<u>340</u>
						<u>limestone</u>	<u>340</u>	<u>360</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>252</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>18</u>
<u>Cement</u>	<u>18</u>	<u>252</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 10-29-1971

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 20 GPM

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 300 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 308 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 11-2-1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Harrold Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT <u>775</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------