

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION SE of SE 1/4 Section or Gov't. Lot Section 21 Township 8N Range 7W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Robert Rathrop

OR - Grid or Street No. Street or Road Name ADDRESS R6W

AND - If available subdivision name, lot & block No. POST OFFICE Eastman Wis ZIP CODE 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump

Septic Tank 50' Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 70' Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>236</u>	<u>6</u>	<u>236</u>	<u>460</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>0</u>	<u>18</u>
<u>lime rock</u>	<u>18</u>	<u>395</u>
<u>shale</u>	<u>395</u>	<u>460</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel PSI 1200</u>	<u>Surface</u>	<u>236</u>
	<u>A-120 Valley steel Pitless adaptor P.E.</u>	<u>18.97</u>	

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>cement</u>	<u>8</u>	<u>236</u>

Well construction completed on 8-31 1983

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 7 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 400 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 405 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 10-26 1983

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kuehner Registered Well Driller Business Name and Complete Mailing Address Box 75
Donswell Drilling Roscoe Wis 53875