

WELL CONSTRUCTOR'S REPORT

DEPARTMENT OF RESOURCE DEVELOPMENT

1. COUNTY Crawford CHECK ONE Town Village City NAME Seneca

2. LOCATION (Number and street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NW 1/4 Sec. 18 T9N R5W

3. OWNER AT TIME OF DRILLING
Lorenzo Sutton Jr.

4. OWNER'S COMPLETE MAIL ADDRESS
R1 Eastman, Mo. 54626

5. Distance in feet from well to nearest:
 (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	TILE	C. I.

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I.	TILE							

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	88	6	88	460	Clay	Surface	10
						sandstone	10	65

8. CASING, LINER, CURBING, AND SCREEN				10. FORMATIONS		
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	88	Clay	65	75
				limestone	75	340
				sandstone	340	460

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	10
Cement	10	88

Well construction completed on 10-16-1968

11. MISCELLANEOUS DATA
 Yield test: 3 Hrs. at 15 GPM Well is terminated 18 inches above below final grade

Depth from surface to normal water level 400 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 400 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison, Wis. laboratory on: 11-5-1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boacobel, Wis. 53805

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
780				