

WELL CONSTRUCTOR'S REPORT

Well-6

JAN - 4 1971

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Seneca Seneca

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NE 1/4 of Sec. 24 T9N R5W

3. OWNER AT TIME OF DRILLING
Albert Roberts

4. OWNER'S COMPLETE MAIL ADDRESS
R70 Seneca Wis. 54654

5. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C.I.	C.I.	C.I.	SEWER CONNECTED	INDEPENDENT
8'	15'			15'

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C.I.	TILE							
	65'			80'	110'	100'	65'	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10"	Surface	103	6	103	400	Clay	Surface	30	
						limestone	30	260	
						sandstone	260	370	
						limestone	370	400	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain ends 19.18	Surface	103

9. GROUT OR OTHER SEALING MATERIAL			
Kind	From (ft.)	To (ft.)	
Clay	Surface	30	
Cement	30	103	

11. MISCELLANEOUS DATA

Yield test: 5 Hrs. at 12 GPM

Well is terminated 12 inches above below final grade

Depth from surface to normal water level 310 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 315 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 12-28-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, R3-Box 84 Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
782				