

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Seneca

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
SW 1/4 of Sec. 27 T9N R5W

3. OWNER AT TIME OF DRILLING Frank Garvey

4. OWNER'S COMPLETE MAIL ADDRESS R7D Seneca, Wis., 54654

5. Distance in feet from well to nearest: (Record answer in appropriate block)

|          |                |             |                  |                   |
|----------|----------------|-------------|------------------|-------------------|
| BUILDING | SANITARY SEWER | FLOOR DRAIN | FOUNDATION DRAIN | WASTE WATER DRAIN |
| C. I.    | TILE           | C. I.       | SEWER CONNECTED  | INDEPENDENT       |
| 125'     |                | 150'        |                  |                   |

|                   |             |       |             |                  |      |      |                |           |
|-------------------|-------------|-------|-------------|------------------|------|------|----------------|-----------|
| CLEAR WATER DRAIN | SEPTIC TANK | PRIVY | SEEPAGE PIT | ABSORPTION FIELD | BARN | SILO | ABANDONED WELL | SINK HOLE |
| C. I.             | TILE        |       |             |                  |      |      |                |           |
|                   | 160'        |       |             | 165'             |      |      |                |           |

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

| 7. DRILLHOLE                          |                                 |          |            |            |          | 10. FORMATIONS  |            |          |
|---------------------------------------|---------------------------------|----------|------------|------------|----------|---|------------|----------|
| Dia. (in.)                            | From (ft.)                      | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind  | From (ft.) | To (ft.) |
| 10                                    | Surface                         | 84       | 6          | 84         | 209      | Clay  | Surface    | 15       |
|                                       |                                 |          |            |            |          | broken sandrock   | 15         | 25       |
|                                       |                                 |          |            |            |          | limestone   | 25         | 60       |
|                                       |                                 |          |            |            |          | poor sandrock   | 60         | 70       |
|                                       |                                 |          |            |            |          | solid sandrock  | 70         | 84       |
| 8. CASING, LINER, CURBING, AND SCREEN |                                 |          |            |            |          | This was a repair job - beyond this point I do not know |            |          |
| Dia. (in.)                            | Kind and Weight                 |          | From (ft.) | To (ft.)   |          |   |            |          |
| 6                                     | new black steel plain end 19.18 |          | Surface    | 84         |          |   |            |          |
| 9. GROUT OR OTHER SEALING MATERIAL    |                                 |          |            |            |          | Well construction completed on <u>4-13-1963</u>         |            |          |
| Kind                                  |                                 |          | From (ft.) | To (ft.)   |          |   |            |          |
| Clay                                  |                                 |          | Surface    | 15         |          |   |            |          |
| Cement                                |                                 |          | 15         | 84         |          |   |            |          |

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 5 GPM Well is terminated 10 inches  above  below final grade

Depth from surface to normal water level 190 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 190 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to \_\_\_\_\_ laboratory on: \_\_\_\_\_ 19

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Hermet Cyprian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

Please do not write in space below

|                      |               |               |           |                       |
|----------------------|---------------|---------------|-----------|-----------------------|
| COLIFORM TEST RESULT | GAS - 24 HRS. | GAS - 48 HRS. | CONFIRMED | REMARKS               |
| 787                  |               |               |           | water sample in. 4-63 |