

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH
See Instructions on Reverse Side

1. County Crawford Town Seneca
Village
City Check one and give name

2. Location 4 miles S. of Seneca Sec 29, T9N, 5W
Name of street and number of premise or Section, Town and Range numbers

3. Owner or Agent Albert White
Name of individual, partnership or firm

4. Mail Address Eastman, Wisconsin P. O.
Complete address required

5. From well to nearest: Building 50 ft; sewer 200 ft; drain 200 ft; septic tank 200 ft;
dry well or filter bed 200 ft; abandoned well 25 ft.

RECEIVED
AUG 28 1958

6. Well is intended to supply water for: farm

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	51	6	51	445

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	standard wt.	0	51

9. GROUT:

Kind	From (ft.)	To (ft.)
Cement	40	51
Clay	0	40

11. MISCELLANEOUS DATA:

Yield test: 3 Hrs. at 10 GPM.
Depth from surface to water-level: 400 ft.
Water-level when pumping: 400 ft.
Water sample was sent to the state laboratory at:
Madison on Aug. 18 1958
City

10. FORMATIONS ENVIRONMENTAL SANITATION

Kind	From (ft.)	To (ft.)
Clay + loose rock	0	10
loose stone	10	25
Clay	25	35
limestone broken	35	40
limestone	40	125
blue stone	125	225
sandstone	225	350
white limestone	350	400
sandstone	400	445

Construction of the well was completed on:
July 25 1958

The well is terminated 6 inches
 above, below the permanent ground surface.

Was the well disinfected upon completion?
Yes No

Was the well sealed watertight upon completion?
Yes No

Signature Kenneth Coplan Registered Well Driller
Please do not write in space below
R3 Box 36 Bossobel, Wis. Complete Mail Address

Rec'd AUG 19 1958 No. 26238

Ans'd _____
Interpretation UNSAFE

10 ml 10 ml 10 ml 10 ml 10 ml
Gas—24 hrs. +
48 hrs. _____
Confirm 1/1/58
B. Coli 4/5
Examiner _____