

AUG 3 1979

State of Wisconsin
Department of Natural Resources
Box 7921
Madison, Wisconsin 53707

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15 Rev. 12-76

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Seneca</u>	
2. LOCATION 1/2 Section <u>SW</u> Section <u>30</u> Township <u>9N</u> Range <u>5W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Bernard J. Jay</u>		ADDRESS <u>RFD Eastman</u>	
OR - Grid or Street No. Street Name		POST OFFICE <u>WV, 54626</u>		AND - If available subdivision name, lot & block No.	
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>75'</u>		Building		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I. Other		C.I. Other	
		C.I. Other		C.I. Other	
		C.I. Other		C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm		C.I. Other		Sewage Sump	
				Clearwater Sump	
				Septic Tank	
				Holding Tank	
				Sewage Absorption Unit <u>150'</u>	
				Seepage Pit	
				Seepage Bed	
				Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Well	
				Pump	
				Tank	
				Subsurface Pumproom	
				Nonconforming Existing	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: <u>Farm home</u>		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.)	
Dia. (in.)		From (ft.)		To (ft.)	
10		Surface		0	
		180		6	
		180		300	
		Clay		Surface	
		soft sandstone		10	
		broken limestone		80	
		hard sandstone		160	
				300	
7. CASING, LINER, CURBING AND SCREEN		Material, Weight, Specification			
Dia. (in.)		From (ft.)		To (ft.)	
6		Surface		0	
		180			
		new black steel		P.F. 18.97	
		A-53		Valley Steel	
				Pitless adapter	
8. GROUT OR OTHER SEALING MATERIAL		Kind		From (ft.)	
		Clay		Surface	
		Cement		8	
				180	
10. TYPE OF DRILLING MACHINE USED		Well construction completed on <u>7-21-</u> <u>1979</u>			
<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air		<input type="checkbox"/> Jetting with	
<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air		<input type="checkbox"/> Air	
<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary		<input type="checkbox"/> Water	
11. MISCELLANEOUS DATA		Yield Test: <u>3</u> Hrs. at <u>5</u> GPM		Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below	
Depth from surface to normal water level <u>270</u> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth of water level when pumping <u>273</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Water sample sent to <u>Madison</u> laboratory on <u>7-30-</u> <u>1979</u>			

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address Boscobel, WV
R2 Box 4 53805

792