

MAR 23 1978

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Seneca

2. LOCATION 1/4 Section NE Section 31 Township 9 N Range 5 W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Dale & Earl Duba

OR - Grid or Street No. Street Name ADDRESS R1

AND - If available subdivision name, lot & block No. POST OFFICE Eastman, Wis., 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 8' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 150' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter 125' Animal Barn Pen Animal Yard Silo With Pit 125' Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Farm Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>285</u>	<u>6</u>	<u>285</u>	<u>420</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>25</u>
<u>limestone</u>	<u>25</u>	<u>75</u>
<u>soft sandstone</u>	<u>75</u>	<u>158</u>
<u>limestone</u>	<u>158</u>	<u>200</u>
<u>soft sandstone</u>	<u>200</u>	<u>260</u>
<u>limestone</u>	<u>260</u>	<u>400</u>
<u>sandstone</u>	<u>400</u>	<u>420</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53 Valley Steel Pitless adaptor</u>	<u>Surface</u>	<u>285</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>285</u>

Well construction completed on Mar. 10 1978

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 5 GPM

Depth from surface to normal water level 315 Ft.

Depth of water level when pumping 345 Ft. Stabilized  Yes  No

Well is terminated 12 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on Mar. 16 1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address Boscobel, Wis. R3 Box 84 53805