

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15
Rev. 10-75

JUN 29 1976

1. COUNTY <i>Crawford</i>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <i>Seneca</i>	
2. LOCATION OR - Grid or Street No. <i>1/4 Section</i> Section <i>14</i> Township <i>9N</i> Range <i>6W</i>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <i>Paul Townsend</i>			
Street Name <i>Village of Lynxville</i>		ADDRESS			
AND - If available subdivision name, lot & block No. <i>LOT 23 BLOCK 15</i>		POST OFFICE <i>Lynxville, WI 54640</i>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <i>8'</i>		Sanitary Bldg. Drain C.I. <i>70'</i> Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	
		Sewage Sump C.I. Other		Clearwater Sump	
		Septic Tank <i>70'</i>		Holding Tank	
		Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench		<i>75'</i>	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
		Barn Gutter		Animal Barn Pen	
		Animal Yard		Silo With Pit	
		Glass Lined Storage Facility		Silo w/o Pit	
		Earthen Silage Storage Trench Or Pit			
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
		Other (Give Description)			
5. Well is intended to supply water for: <i>Home</i>		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		<i>Clay</i>		<i>Surface 0 12</i>	
<i>10 0 Surface 73 6 73 120</i>		<i>Loose stone & Clay</i>		<i>12 35</i>	
		<i>Soft Shalestone</i>		<i>35 50.</i>	
		<i>Hardshale stone</i>		<i>50 120</i>	
7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly		From (ft.) To (ft.)			
Dia. (in.)		From (ft.) To (ft.)			
<i>6" New Blacksteel plain end 18.97 A-53</i>		<i>0 Surface 73</i>			
<i>Valley steel</i>					
<i>Pitless adaptor</i>					
8. GROUT OR OTHER SEALING MATERIAL		Kind		From (ft.) To (ft.)	
		<i>Clay</i>		<i>0 Surface 7</i>	
		<i>Cement</i>		<i>7 73</i>	
11. MISCELLANEOUS DATA		Yield Test: <i>4</i> Hrs. at <i>5</i> GPM		Well is terminated <i>12</i> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below	
Depth from surface to normal water level <i>80</i> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping <i>86</i> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to <i>Madison</i>		laboratory on <i>June 21</i>		<i>19 76</i>	

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature

Kenneth Copson Registered Well Driller

Complete Mail Address

*Route 3, Box 84
Boscobel, WI 53805*

817