

MAR 9 1983

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Eastman

2. LOCATION NW of NE Section 36 Township 8N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Richard DuCharme

OR - Grid or Street No. or NESE? Street or Road Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Waupesa ZIP CODE WI 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to Sewer Sewage Sump Clearwater Dr. Clearwater Sump Sewage Sump Clearwater Sump Clearwater Sump Clearwater Sump Clearwater Sump

Septic Tank 250' Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 260' Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter 070' Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin 255'

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Farm

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0 Surface	386	6	386	520

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	new black steel PE 18.97	0 Surface	386
	A-53 Valley Steel Pitless adaptor		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
clay	Surface	8
lime rock	8	200
sand rock	200	255
lime rock	255	520

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	0 Surface	8
cement	8	386

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well construction completed on 1-5 1983

Well is terminated 12 inches  above final grade  below

Depth from surface to normal water level 450 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 454 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 1-12 1983

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschbaum Registered Well Driller Business Name and Complete Mailing Address Box 75  
Dons Well Drilling Boscobel WI 53805

82