

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Seneca</u>	
2. LOCATION 1/4 Section <u>SE</u> Section <u>23</u> Township <u>9N</u> Range <u>6W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Stanley Hagensick</u>		ADDRESS <u>Lynsville</u>	
OR - Grid or Street No. Street Name		POST OFFICE <u>WV., 54640</u>		AND - If available subdivision name, lot & block No. <u>Lot no. 13</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>15'</u>	Sanitary Bldg. Drain C.I. Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer
Street Sewer San. Storm		Other Sewers C.I. Other	Foundation Drain Connected to: Sewage Sump Clearwater Dr.	Sewage Sump C.I. Other	Clearwater Sump
Septic Tank		Holding Tank	Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench		
Privy	Pet Waste Pit	Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen Animal Yard Silo With Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
5. Well is intended to supply water for: <u>Trailer home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>87</u>	<u>6</u>	<u>87</u>	<u>120</u>
			<u>Clay & Stone</u>		
			<u>hard shalestone</u>		
			<u>sandstone</u>		
7. CASING, LINER, CURBING AND SCREEN			From (ft.)		
Material, Weight, Specification & Method of Assembly			To (ft.)		
Dia. (in.)					
<u>6</u>	<u>new black steel P.E. 18.97</u>		<u>0</u> Surface		<u>87</u>
<u>A-53</u>					
<u>Kent Steel</u>					
<u>Bitless adapter</u>					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind			From (ft.)		
To (ft.)			To (ft.)		
<u>Clay</u>			<u>0</u> <u>8</u>		
<u>Cement</u>			<u>8</u> <u>87</u>		
			Well construction completed on <u>7-17</u> 19 <u>79</u>		
11. MISCELLANEOUS DATA			Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Yield Test: <u>3</u> Hrs. at <u>5</u> GPM			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level <u>60</u> Ft.			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>68</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <u>Madison</u> laboratory on <u>7-31-</u> 19 <u>79</u>					

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address R2 Box 4 Boscobel WV, 53805