

AUG 23 1976

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
 Form 3300-15
 Rev. 10-75

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <u>Seneca</u>										
2. LOCATION 1/2 Section <u>NW</u> Section <u>23</u> OR - Grid or Street No. Street Name		Township <u>9N</u> Range <u>6W</u>		3. NAME <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Gayland Phillips</u> <u>Lynxville</u> <u>Wis., 54640</u>											
AND - If available subdivision name, lot & block No.		POST OFFICE													
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>7'</u>	Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other <u>10'</u>										
Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit <u>70'</u>	
San. Storm		C.I. Other		Sewer		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit	
Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard		Silo With Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)					
5. Well is intended to supply water for: <u>Trailer home</u>				9. FORMATIONS											
6. DRILLHOLE				Kind				From (ft.)		To (ft.)					
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)				<u>Clay</u>				<u>Surface</u>		<u>12</u>					
<u>10 Surface 46 6 4-6 100</u>				<u>loose rock & sand</u>				<u>12</u>		<u>30</u>					
				<u>sandstone</u>				<u>30</u>		<u>60</u>					
				<u>shalestone</u>				<u>60</u>		<u>100</u>					
7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly				Dia. (in.) From (ft.) To (ft.)											
<u>6 new black steel PE 18.97</u>				<u>Surface</u>				<u>46</u>							
<u>A-53</u>															
<u>Valley Steel</u>															
<u>Pitless adapter</u>															
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED											
Kind From (ft.) To (ft.)				<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water											
<u>Cement</u> <u>Surface</u> <u>46</u>				Well construction completed on <u>7-29-</u> 19 <u>76</u>											
11. MISCELLANEOUS DATA				Well is terminated <u>8</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below											
Yield Test: <u>3</u> Hrs. at <u>6</u> GPM				Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No											
Depth from surface to normal water level <u>15</u> Ft.				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No											
Depth of water level when pumping <u>15</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No															
Water sample sent to <u>Madison</u> laboratory on <u>8-16-</u> 19 <u>76</u>															
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.															
Signature <u>823 Kenneth Coplan</u> Registered Well Driller				Complete Mail Address <u>Boscobel, Wis. 53805</u>											