

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

Wsl 6

See Instructions on Reverse Side

RECEIVED

1. County Crawford Town Village Lynxville City Check one and give name APR 20 1966

2. Location 212 Main - B-4-416 - NW 1/4 NW 1/4 Sec 23 - T9N R6W
Name of street and number of premise or Section, Town and Range numbers

3. Owner or Agent Milo Harris
Name of individual, partnership or firm

4. Mail Address 212 Main St. Lynxville Wis
Complete address required

5. From well to nearest: Building 8 ft; sewer ft; drain ft; septic tank 40 ft;
 dry well or filter bed ft; abandoned well ft.

6. Well is intended to supply water for: Bait Shop

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
8"	0	42	4"	42	73

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
4"	11# Steel	0	42

9. GROUT:

Kind	From (ft.)	To (ft.)
Cement	42	40

11. MISCELLANEOUS DATA:

Yield test: 10 Hrs. at 8 GPM.

Depth from surface to water-level: 10 ft.

Water-level when pumping: 35 ft.

Water sample was sent to the state laboratory at:

Madison on 4/13 1966
City

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
Clay + Shale	0	34
Sandstone	34	73

Construction of the well was completed on:

4/1 1966

The well is terminated 14 inches above, below the permanent ground surface.

Was the well disinfected upon completion?

Yes No

Was the well sealed watertight upon completion?

Yes No

Signature Edwin W. Meyer Registered Well Driller

New alb. Iowa Complete Mail Address

Please do not write in space below

Rec'd APR 14 1966 No. 49393

Ans'd APR 18 1966

Interpretation Safe

Bacteriologically

10 ml 10 ml 10 ml 10 ml 10 ml

Gas—24 hrs.

48 hrs.

Confirm

B. Coli 0 0 0 0 0

Examiner