

AUG 23 1976

SE 16 1976

NOTE:  
White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
Form 3300-15  
Rev. 10-75

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Lynville

2. LOCATION NE 23 9W 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
OR - Grid or Street No. Street Name ADDRESS Robert A. Hagensick  
Box 172

AND - If available subdivision name, lot & block No. POST OFFICE Lynville, Wis. 54640  
Armstrong addition

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
40'	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
San. Storm C.I. Other	Sewer Clearwater Dr.	Sewage Sump Clearwater Sump	C.I. Other				Seepage Pit Seepage Bed Seepage Trench
					60'		70'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: None

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	47	6	47	60	Clay	Surface	35
						hard shalestone	35	60

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53	Surface	47
	Valley Steel Pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	47

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Reverse Rotary  Jetting with  Air  Water

Well construction completed on 7-30- 19 76

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches  above  below final grade

Depth from surface to normal water level 35 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 40 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 8-17- 19 76

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller

Complete Mail Address Boscobel, Wis. 53805  
R3 Box 84