

# First Water Quality Test For WISCONSIN UNIQUE WELL NUMBER BA 669


State of Wisconsin  
Department of Natural Resources  
Private Water Supply - WS/2  
Box 7921  
Madison, WI 53707

JUL 25 1989

Property Owner: Jim Jenkins/Kerry Grant Telephone Number: 8608 872-2419  
Mailing Address: R.R. 2 Box 83  
City: Gays Mills WI State: WI Zip Code: 54631  
County: Crawford County Well Location Permit No.: W Well Completion Date: 7/17/89  
M M D D Y Y

1. Location (Please type or print using a black pen.)  
 Town  City  Village Fire # (if available)  
of Scott  
Grid or Street Address or Road Name and Number (if available)  
Subdivision Name Lot # Block #

Well Constructor (Business Name) Registration #  
Corpian Well Drilling Inc 75  
Address  
501 E. LAK ST.  
City State Zip Code  
Boscobel WI 53805



Gov't Lot # or S1/4 of SE 1/4 of ???  
Section 3; T 9 N; R 3  E  W

3. Well Type  New  
 Replacement  Reconstruction/Rehabilitation  
of well constructed in 19: \_\_\_\_\_

4. Well serves 2 of homes and/or \_\_\_\_\_  
(ex: barn, restaurant, church, school, industry, etc.)

High Capacity Well?  Yes  No  
High Capacity Property?  Yes  No

Reason for new, reconstructed, replaced, or rehabilitated well?  
Used Neighbors  
 Drilled  Driven Point  Jetted  Other \_\_\_\_\_

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings?  Yes  No  
Well Located in Floodplain?  Yes  No  
Distance In Feet From Well To Nearest:  
100+  
1. Landfill \_\_\_\_\_ 2. Building Overhang 100+  
3. Septic or Holding Tank \_\_\_\_\_ 4. Sewage Absorption Unit \_\_\_\_\_  
5. Nonconforming Pit \_\_\_\_\_ 6. Buried Home Heating Oil Tank \_\_\_\_\_  
7. Buried Petroleum Tank \_\_\_\_\_ 8. Shoreline/Swimming Pool \_\_\_\_\_  
9. Downspout/Yard Hydrant \_\_\_\_\_ 10. Privy \_\_\_\_\_  
11. Foundation Drain to Clearwater \_\_\_\_\_ 12. Foundation Drain to Sewer \_\_\_\_\_  
13. Building Drain \_\_\_\_\_  
 Cast Iron or Plastic  Other \_\_\_\_\_  
14. Building Sewer  Gravity  Pressure  
 Cast Iron or Plastic  Other \_\_\_\_\_  
15. Collector Sewer \_\_\_\_\_ 16. Clearwater Sump \_\_\_\_\_  
17. Wastewater Sump \_\_\_\_\_ 18. Paved Animal Barn Pen \_\_\_\_\_  
19. Animal Yard or Shelter \_\_\_\_\_ 20. Silo - Type \_\_\_\_\_  
21. Barn Gutter \_\_\_\_\_ 22. Manure Pipe  Gravity  Pressure  
 Cast Iron or Plastic  Other \_\_\_\_\_  
23. Other Manure Storage \_\_\_\_\_ Other NR 112 Waste Source \_\_\_\_\_  
24. \_\_\_\_\_

6. Drillhole Dimensions

Dia. (in.)	From (ft.)	To (ft.)
10	surface	45
6	45	100

Method of constructing upper enlarged drillhole. (If applicable check more than one.)

1. Rotary - Mud Circulation  
 2. Rotary - Air  
 3. Rotary - Foam  
 4. Reverse Rotary  
 5. Cable-tool Bit \_\_\_\_\_ in. dia.  
 6. Temp. Outer Casing \_\_\_\_\_ in. dia.  
Removed?  Yes  No  
If no, explain \_\_\_\_\_  
 7. Other \_\_\_\_\_

9. Geology

Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
I - dirt	surface	9
SH - soft shale	9	43
HH - hard shale	43	100

7. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	New Black steel Plain End	surface	45
	ERW ASTM A53A		
	#18.97 20x21		
Dia. (in.)	screen type and material	From	To

10. Static Water Level  
ft. above ground level  
38 ft. below ground surface

11. Pump Test  
Pumping Level 92 ft. below surface  
Pumping at 7 GPM for 2 hours

12. Well Is:  
20 in.  Above Grade  Below Grade  
Developed?  Yes  No  
Disinfected?  Yes  No  
Capped?  Yes  No

8. Grout or Other Sealing Material

Method	From (ft.)	To (ft.)	Sacks Cement
Tramee	surface	45	10
Neat Cement	surface	45	10

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?  
 Yes  No If no, explain None

14. Signature of Well Constructor Michael D. Beinhorn MB Date Signed 7-23-89  
Signature of Drill Rig Operator Michael D. Beinhorn MB Date Signed 7-23-89