

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Seneca</u>	
2. LOCATION 1/4 Section <u>NW</u> Section <u>24</u> Township <u>9N</u> Range <u>6W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>James Crunson</u>		ADDRESS <u>R7D</u>	
OR - Grid or Street No. Street Name		AND - If available subdivision name, lot & block No.		POST OFFICE <u>Lynxville, Wis., 54640</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>8'</u>	Sanitary Bldg. Drain C.I. <u>20'</u> Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer
Street Sewer San. Storm		Other Sewers C.I. Other	Foundation Drain Connected to: Sewer Clearwater Dr.	Sewage Sump C.I. Other	Clearwater Sump Septic Tank <u>48'</u> Holding Tank
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumproom Nonconforming Existing	Barn Gutter Animal Barn Pen Animal Yard	Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit
Temporary Manure Stack		Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)
5. Well is intended to supply water for: <u>Trailer home</u>		9. FORMATIONS			
6. DRILLHOLE		Dia. (in.)		From (ft.) To (ft.)	
Dia. (in.)		From (ft.)		To (ft.)	
<u>10</u>	<u>Surface</u>	<u>0</u>	<u>74</u>	<u>6</u>	<u>74</u>
7. CASING, LINER, CURBING AND SCREEN		Material, Weight, Specification & Method of Assembly		From (ft.) To (ft.)	
Dia. (in.)		From (ft.)		To (ft.)	
<u>6</u>	<u>new black steel R.E. 18.97</u>	<u>Surface</u>	<u>0</u>	<u>74</u>	
	<u>A-53</u>				
	<u>Valley Steel</u>				
	<u>Pitless adaptor</u>				
8. GROUT OR OTHER SEALING MATERIAL		Kind		From (ft.) To (ft.)	
Kind		From (ft.)		To (ft.)	
<u>Clay</u>		<u>Surface</u>		<u>7</u>	
<u>Cement</u>		<u>7</u>		<u>74</u>	
11. MISCELLANEOUS DATA		Yield Test: <u>4</u> Hrs. at <u>5</u> GPM		Well construction completed on <u>3-31-</u> <u>1978</u>	
Depth from surface to normal water level <u>50</u> Ft.		Well is terminated <u>10</u> inches		<input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below	
Depth of water level when pumping <u>56</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Water sample sent to <u>Madison</u> laboratory on <u>4-17-</u> <u>1978</u>		Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.			
Signature <u>Kenneth Coplan</u> 833		Complete Mail Address <u>R3 Box 84</u> <u>Boscobel, Wis.</u> <u>53805</u>			