

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

AUG 1 9 1977

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Seneca

2. LOCATION SW 27 T9N R6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Ray Tirado

OR - Grid or Street No. Street Name ADDRESS

AND - If available subdivision name, lot & block No. POST OFFICE Synsville, Wi

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>10</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
San. Storm	C.I. Other	Sewer	C.I. Other	Clearwater Sump			Seepage Pit Seepage Bed Seepage Trench
		Clearwater Dr.					<u>75</u>

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well Pump Tank	Nonconforming Existing							

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)

5. Well is intended to supply water for: Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>70</u>			
<u>6</u>	<u>70</u>	<u>144</u>			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>10</u>
<u>sand + gravel</u>	<u>10</u>	<u>70</u>
<u>Dolomite</u>	<u>70</u>	<u>130</u>
<u>sandstone</u>	<u>130</u>	<u>144</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6"</u>	<u>New Steel TC 19.45</u>	<u>Surface</u>	<u>70</u>
	<u>A-53 Youngstown</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Cement</u>	<u>Surface</u>	<u>70</u>

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on 7-26 1977

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 40 GPM

Depth from surface to normal water level 15 Ft.

Depth of water level when pumping 40 Ft. Stabilized Yes No

Well is terminated 8 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Aug 11 1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph J. Faherty Registered Well Driller

Complete Mail Address FAHERTY DRILLING CO., INC.
 1120 Broadway
 PLATTEVILLE, WISCONSIN