

SEP 24 1981
WCD

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Scott

2. LOCATION NW Section 3 Township 9N Range 3W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Jack Zuhaty

OR - Grid or Street No. Street or Road Name ADDRESS 624 Forest Ave

AND - If available subdivision name, lot & block No. POST OFFICE Elgin, Ill ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 75' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench Manure Hopper or Retention or Pneumatic Tank 200

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	Kind	From (ft.)	To (ft.)
10	Surface	182	6"	182	400	clay	Surface	0	30
						limestone		30	90
						sandstone		90	170
						limestone		170	240
						hard shalestone		240	400

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	A-53 P.E. 18.97 #/ft. pitless adapter Kent Steel	Surface	182

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	182

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 6-25 1981

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 8 GPM Well is terminated 18 inches above final grade below

Depth from surface to normal water level 320 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 330 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 9-21 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature [Signature] Registered Well Driller Business Name and Complete Mailing Address Kenneth Corpean & Sons, Inc
Rt. 2 Box 4 Boonville, WI 53805