

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

AUG 7 1979

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Clayton

2. LOCATION SW Section 3 Township 10 N Range 3 W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
 ADDRESS Bill Meyers  
R 7 D 3 Gaule Mills,  
Wis., 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 8' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 30'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	179	6	179	240

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay & stone	Surface	6
hard limestone	6	100
soft sandstone	100	155
hard shale stone	155	210
sandstone	210	240

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53	Surface	179
	Kent Steel		
	Pitless adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	8
Cement	8	179

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Reverse Rotary  Jetting with  Air  Water

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 5 GPM

Depth from surface to normal water level 80 Ft.

Depth of water level when pumping 205 Ft. Stabilized  Yes  No

Well construction completed on 7-11-1979

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 8-2-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Hermith Copian Registered Well Driller Complete Mail Address Boscobel, Wis., R2 Box 4 53805

845