

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

7780

SEP 21 1972

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY <i>Crawford</i>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			NAME <i>Clayton</i>	
2. LOCATION - 1/4 Section <i>SE</i> Section <i>3</i> Township <i>10N</i> Range <i>3W</i>		3. OWNER AT TIME OF DRILLING <i>Joe Gander</i>				
OR - Grid or street no.		Street name			ADDRESS <i>R7D</i>	
AND - If available subdivision name, lot & block no.		POST OFFICE <i>Soldiers Grove 54655</i>				
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	WASTE WATER DRAIN TILE
		<i>20'</i>				
CLEAR WATER DRAIN C.I.	SEPTIC TANK TILE	PRIVY C.I.	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO
		<i>60'</i>				
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)						

5. Well is intended to supply water for: *Country Home*

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<i>10</i>	<i>Surface</i>	<i>170</i>	<i>6</i>	<i>170</i>	<i>260</i>	<i>Clay</i>	<i>Surface</i>	<i>15</i>
						<i>soft sandstone</i>	<i>15</i>	<i>90</i>
						<i>broken stone & clay</i>	<i>90</i>	<i>160</i>
						<i>limestone</i>	<i>160</i>	<i>240</i>
						<i>sandstone</i>	<i>240</i>	<i>260</i>

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)					
<i>Clay</i>	<i>Surface</i>	<i>15</i>	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Jetting with	<input type="checkbox"/> Air <input type="checkbox"/> Water
<i>Cement</i>	<i>15</i>	<i>170</i>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air			
				Well construction completed on <i>9-14-1972</i>			

11. MISCELLANEOUS DATA		Yield test: <i>3</i> Hrs. at <i>6</i> GPM		Well is terminated <i>12</i> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade	
Depth from surface to normal water level <i>200</i> ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth to water level when pumping <i>208</i> ft.		Water sample sent to <i>Madison</i> laboratory on: <i>9-18-1972</i>			

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Benneth Copian</i> Registered Well Driller	COMPLETE MAIL ADDRESS <i>Boscobel, Wis., 53805</i>
Please do not write in space below	

COLIFORM TEST RESULT <i>846</i>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------