

JUN 10 1975

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City North Clayton NAME

2. LOCATION - 1/4 Section SE Section 3 Township 10N Range 3W 3. OWNER AT TIME OF DRILLING Donald Ayers
OR - Grid or street no. Street name ADDRESS R1 54655

AND - If available subdivision name, lot & block no. POST OFFICE Soldiers Grove, Wis.

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	SEWER CONNECTED	INDEPENDENT
<u>25'</u>				

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
		<u>70'</u>						

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>42</u>	<u>6</u>	<u>42</u>	<u>100</u>	<u>Clay</u>		<u>Surface</u>	<u>15</u>
						<u>sandstone</u>		<u>15</u>	<u>100</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>42</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>15</u>
<u>Cement</u>	<u>15</u>	<u>42</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 5-15 19 75

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 5 GPM

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 63 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 72 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 6-5-1975

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coyler Registered Well Driller COMPLETE MAIL ADDRESS Boo cobel R3 Box 84 Wis. 53805

COLIFORM TEST RESULT 848 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS

REV. 3-71