

1. COUNTY **CRAWFORD** CHECK (✓) ONE:  Town  Village  City Name **SCOTT**

2. LOCATION **SE** 1/4 Section or Gov't. Lot Section **10** Township **T9NR3W** 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE **KIETH WELDER**

OR - Grid or Street No. Street or Road Name ADDRESS **RR BOX 133**

AND - If available subdivision name, lot & block No. POST OFFICE **BOSCOBEL, WI.** ZIP CODE **53805**

4. Distance in feet from well to nearest: (Record answer in appropriate block) **100'**

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer			
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other		
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		
											Manure Hopper or Automatic Tank		
Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin		Other (Describe)						
					Concrete Floor Only	Concrete Floor and Partial Concrete Walls							

5. Well is intended to supply water for: **COUNTRY HOME**

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	Surface	43			
6"	43	125			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6"	NEW BLACK STEEL PLAIN END	Surface	0	43
	A-53	18.97		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
CEMENT	Surface	43

9. FORMATIONS

Kind	From (ft.)	To (ft.)
CLAY-STONE	0 Surface	10
SOFT SHALESTONE	10	20
HARD SHALESTONE	20	70
HARD SANDSTONE	70	125

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on **5-10** 19**84**

11. MISCELLANEOUS DATA

Yield Test: **2** Hrs. at **8** GPM Well is terminated **10** inches  above final grade  below

Depth from surface to normal water level **60** Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping **65** Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to **MADISON** laboratory on **5-16** 19**84**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature: **Keith Copier** Registered Well Driller Business Name and Complete Mailing Address: **CORPIAN WELL DRILLING RT. 2 BOX 4 BOSCOBEL, WI. 53805**