

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

RECEIVED

See Instructions on Reverse Side

JUN 16 1964

1. County Crawford Town  Clayton  
 Village  City  Check one and give name  
 2. Location Section 5 Town 10 N R 3 W Name of street and number of premise or Section, Town and Range numbers  
 3. Owner  or Agent  Joe Monahan Name of individual, partnership or firm  
 4. Mail Address R 7 D Soldiers Grove, Wis. Complete address required  
 5. From well to nearest: Building 6 ft; sewer 0 ft; drain 0 ft; septic tank 0 ft;  
 dry well or filter bed 0 ft; abandoned well 0 ft.

6. Well is intended to supply water for: Township garage

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
6	0	80			

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	Standard wt	0	56

9. GROUT:

Kind	From (ft.)	To (ft.)
none		

11. MISCELLANEOUS DATA:

Yield test: 4 Hrs. at 12 GPM.  
 Depth from surface to water-level: 30 ft.  
 Water-level when pumping: 35 ft.  
 Water sample was sent to the state laboratory at:  
Madison on June 30 1964  
 City

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
Clay & black dirt	0	15
loose sand	15	35
sandstone	35	60
hard shale stone	60	80

Construction of the well was completed on:

June 8 1964

The well is terminated 10 inches  
 above, below  the permanent ground surface.

Was the well disinfected upon completion?  
 Yes  No

Was the well sealed watertight upon completion?  
 Yes  No

Signature Kenneth Coplan Registered Well Driller R3 Box 36 Bossobel, Wis. Complete Mail Address 53805  
 Please do not write in space below

Rec'd July 1 - 1964 No. 27643  
 Ans'd \_\_\_\_\_  
 Interpretation \_\_\_\_\_

	10 ml	10 ml	10 ml	10 ml	10 ml
Gas—24 hrs.					
48 hrs.					
Confirm					
B. Coli	0	0	0	0	0
Examiner					

SAFE—BACTERIOLOGICALLY