

AUG 4 1976

State of Wisconsin
Department of Natural Resources
Box 450
Madison, Wisconsin 53701

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15
Rev. 10-75

AUG 3 1 1976

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION 1/4 Section SW Section 10 Township 10N Range 3W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Dale Kluka
OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, WI 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 20' Sanitary Bldg. Drain C.I. 35' Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 75' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0 Surface	234	6	234	290

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Soft Sand	0 Surface	20
Sandstone	20	100
Limestone	100	200
Soft Sandstone	200	250
Shalestone	250	280
Limestone	280	290

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	PE New Blacksteel A-53 18.97 Valley steel Pitless adaptor	0 Surface	234

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	0 Surface	7
Cement	7	234

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Rotary-air w/drilling mud Rotary-w/drilling mud Rotary-hammer w/drilling mud & air Reverse Rotary Jetting with Air Water

11. MISCELLANEOUS DATA
Yield Test: 3 Hrs. at 5 GPM
Depth from surface to normal water level 200 Ft.
Depth of water level when pumping 210 Ft. Stabilized Yes No

Well construction completed on July 10 1976
Well is terminated 10 inches above below final grade
Well disinfected upon completion Yes No
Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on July 28 1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 859
Denneth Boyman Registered Well Driller

Complete Mail Address
R3, Box 84 Escobedo, WI 53805