

APR 16 1974

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION - 1/4 Section SE Section 12 Township 10 N Range 3 W

OR - Grid or street no. Street name ADDRESS Jerry Corner R3

AND - If available subdivision name, lot & block no. POST OFFICE Soldiers Grove Wis.

3. OWNER AT TIME OF DRILLING Jerry Corner

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY C. I.	SEWER TILE	FLOOR DRAIN C. I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
<u>20</u>	<u>30</u>							

CLEAR WATER DRAIN C. I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		<u>70'</u>			<u>85'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>155</u>	<u>6</u>	<u>155</u>	<u>440</u>	<u>Clay</u>	<u>Surface</u>	<u>40</u>	
						<u>Clay & loose stone</u>	<u>40</u>	<u>130</u>	
						<u>hard limestone</u>	<u>130</u>	<u>240</u>	
						<u>hard shale stone</u>	<u>240</u>	<u>410</u>	
						<u>sandstone</u>	<u>410</u>	<u>440</u>	

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)		<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	
<u>Clay</u>	<u>Surface</u>	<u>40</u>		<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water	
<u>Cement</u>	<u>40</u>	<u>155</u>		Well construction completed on <u>3-19-1974</u>			

11. MISCELLANEOUS DATA			
Yield test:	<u>3</u> Hrs. at	<u>8</u> GPM	Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level	<u>360</u> ft.	Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	<u>368</u> ft.	Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison laboratory on: 4-1-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Bozobel, R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>862</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				