

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

OCT 17 1973

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION - 1/4 Section NE Section 12 Township 10N Range 3W 3. OWNER AT TIME OF DRILLING Raymond Steiner
OR - Grid or street no. Street name ADDRESS RI

AND - If available subdivision name, lot & block no. POST OFFICE Soldiers Grove 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C.I.	C.I.	C.I.	SEWER CONNECTED	INDEPENDENT
TILE	TILE	TILE		
<u>15'</u>	<u>22'</u>	<u>22'</u>		

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C.I.	TILE							
	<u>70'</u>			<u>80'</u>	<u>50'</u>			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>48</u>	<u>6</u>	<u>48</u>	<u>100</u>	<u>Clay</u>	<u>Surface</u>	<u>25</u>	
						<u>limestone</u>	<u>25</u>	<u>50</u>	
						<u>hard shalestone</u>	<u>50</u>	<u>80</u>	
						<u>sandstone</u>	<u>80</u>	<u>100</u>	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>48</u>

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>Clay</u>	<u>Surface</u>	<u>25</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>25</u>	<u>48</u>	Well construction completed on <u>10-3-1973</u>		

11. MISCELLANEOUS DATA		Well is terminated		Well disinfected upon completion		Well sealed watertight upon completion	
Yield test:	<u>3</u> Hrs. at <u>8</u> GPM	<u>10</u> inches	<input checked="" type="checkbox"/> above <input type="checkbox"/> below	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level	<u>60</u> ft.						
Depth to water level when pumping	<u>6.3</u> ft.						

Water sample sent to Madison laboratory on: 10-11-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Cospian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, Wis, 53805
R3 Box 84

COLIFORM TEST RESULT 863 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS
REV. 3-71