

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

21709

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION - 1/4 Section NE Section 16 Township 10 N Range 3 W
OR - Grid or street no. Street name
3. OWNER AT TIME OF DRILLING Mrs. Joe Monahan
ADDRESS R2

AND - If available subdivision name, lot & block no. POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	C. I.	C. I.	SEWER CONNECTED	INDEPENDENT
<u>8'</u>	<u>15'</u>			

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	<u>70'</u>			<u>80'</u>	<u>150'</u>		<u>40'</u>	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>145</u>	<u>6</u>	<u>145</u>	<u>245</u>	<u>Clay</u>	<u>Surface</u>	<u>15</u>
						<u>soft sandstone</u>	<u>15</u>	<u>80</u>
						<u>limestone</u>	<u>80</u>	<u>140</u>
						<u>blue limestone</u>	<u>140</u>	<u>210</u>
						<u>sandstone</u>	<u>210</u>	<u>245</u>

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>145</u>

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>Clay</u>	<u>Surface</u>	<u>15</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>15</u>	<u>145</u>	Well construction completed on <u>4-27-1973</u>		

11. MISCELLANEOUS DATA
Yield test: 3 Hrs. at 8 GPM
Well is terminated 12 inches above below final grade
Well disinfected upon completion Yes No
Well sealed watertight upon completion Yes No

Depth from surface to normal water level 190 ft.
Depth to water level when pumping 198 ft.
Water sample sent to Madison laboratory on: 5-9-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boocobel, Wis., 53805
Please do not write in space below

COLIFORM TEST RESULT <u>865</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------