

WELL CONSTRUCTOR'S REPORT

WISCONSIN STATE BOARD OF HEALTH

Wel 6



1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available) N W 1/4 S W 1/4 Sec. 21 T.10 N., R.3 W

3. OWNER AT TIME OF DRILLING State Highway Commission Of Wisconsin

4. OWNER'S COMPLETE MAIL ADDRESS State Office Building Madison, Wisconsin

5. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN
 (Record answer in appropriate block) C. I. TILE C. I. TILE SEWER CONNECTED INDEPENDENT C. I. TILE

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
 C. I. TILE 13 120

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Wayside No. 4

| 7. DRILLHOLE | | | | | | 10. FORMATIONS | | |
|--------------|------------|----------|------------|------------|----------|---------------------------------|------------|----------|
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) |
| 10 | Surface | 171 | 6 | 171 | 375 | red clay drift | Surface | 30 |
| | | | | | | rock & clay layers some caveing | 30 | 155 |

| 8. CASING, LINER, CURBING, AND SCREEN | | | | | | |
|---------------------------------------|-----------------|------------|----------|------------------------------|-----|-----|
| Dia. (in.) | Kind and Weight | From (ft.) | To (ft.) | | | |
| 10 | steel 41.1b. | Surface | 47 | yellow sandstone dry | 175 | 325 |
| 6 | steel 19.18 | 18" | 171 | fine green sandstone dry | 325 | 360 |
| | | | | grey sandstone water bearing | 360 | 375 |

| 9. GROUT OR OTHER SEALING MATERIAL | | | | | |
|------------------------------------|------------|----------|--|--|--|
| Kind | From (ft.) | To (ft.) | | | |
| neat cement pressure grout | Surface | 171 | | | |

| 11. MISCELLANEOUS DATA | | | | | |
|--|-----|---------|---|-----|---|
| Yield test: | 6 | Hrs. at | 5 | GPM | Well is terminated 18 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade |
| Depth from surface to normal water level | 246 | ft. | | | Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Depth to water level when pumping | 248 | ft. | | | Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |

Water sample sent to Madison laboratory on: 10-4 1966

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE E. Sperling & Sons Inc. COMPLETE MAIL ADDRESS Box D Iron Ridge, Wisconsin
Elmer S. Sperling Pres. Registered Well Driller

Please do not write in space below

| COLIFORM TEST RESULT | GAS - 24 HRS. | GAS - 48 HRS. | CONFIRMED | REMARKS |
|----------------------|---------------|---------------|-----------|---------|
| 871 | | | | |