

NOV 5 1979

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Clayton

2. LOCATION 1/4 Section SE Section 21 Township 10N Range 3W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Joe Burke  
 OR - Grid or Street No. Street Name ADDRESS R1 Box 223A

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 20' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Sump Clearwater Sump Sewage Absorption Unit 80' Seepage Pit Seepage Bed Seepage Trench

Septic Tank 75' Holding Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphouse Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Wis. Pride Cheese, Inc.

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	81	6	81	580

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	Surface	20
broken limestone	20	55
hard limestone	55	190
hard sandstone	190	275
hard shalestone	275	440
hard sandstone	440	580

7. CASING, LINER, CURBING AND SCREEN  
 Material, Weight, Specification  
 Dia. (in.) & Method of Assembly From (ft.) To (ft.)

6	new black steel P.E. 18.97	Surface	81
A-53 Keystone Pipe Pitless Adapter			

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	8
Cement	8	81

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 29 GPM

Depth from surface to normal water level 420 Ft.

Depth of water level when pumping 480 Ft. Stabilized  Yes  No

Well construction completed on 10-9-1979

Well is terminated 10 inches  above final grade  below

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 10-29-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Espino Registered Well Driller Complete Mail Address R2 Box 4 Boscobel, Wis. 53805