

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION SW Section 24 Township 10N Range 3W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
OR - Grid or Street No. Street Name ADDRESS James S. Morgan
R2

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 50' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Holding Tank Septic Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 110'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

9. FORMATIONS

6. DRILLHOLE		From (ft.)		To (ft.)	
Dia. (in.)					
<u>10</u>	<u>Surface</u>	<u>189</u>	<u>6</u>	<u>189</u>	<u>450</u>

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>0</u>	<u>20</u>
<u>limestone</u>	<u>20</u>	<u>120</u>
<u>soft sandstone</u>	<u>120</u>	<u>170</u>
<u>hard shalestone</u>	<u>170</u>	<u>450</u>

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly From (ft.) To (ft.)
6 new black steel P.E. 18.97 Surface 189
A-53
Valley Steel
Pitless adaptor

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Rotary-air w/drilling mud Rotary-w/drilling mud Rotary-hammer w/drilling mud & air Reverse Rotary Jetting with Air Water

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)
Clay Surface 7
Cement 7 189

Well construction completed on 8-5-77

11. MISCELLANEOUS DATA Yield Test: 3 Hrs. at 5 GPM
Depth from surface to normal water level 355 Ft.
Depth of water level when pumping 375 Ft. Stabilized Yes No

Well is terminated 10 inches above below final grade
Well disinfected upon completion Yes No
Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-29-77

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, Wis. R3 Box 84 53805

874