

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

NOV 19 1979

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION 1/4 Section NW Section 32 Township 10 N Range 3 W
OR - Grid or Street No. Street Name ADDRESS Ellery Teach
R7D

AND - If available subdivision name, lot & block No. POST OFFICE Sage Mills, Wis., 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 10' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Flood Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to Sewage Sump Clearwater Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 75'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country Home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	105	6	105	320	Clay & stone	Surface	35
						limestone	35	70
						Clay	70	85

7. CASING, LINER, CURBING AND SCREEN			
Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53	Surface	105

Keystone Pipe
Pitless Adapter

8. GROUT OR OTHER SEALING MATERIAL			
Kind	From (ft.)	To (ft.)	
Clay	Surface	8	
Cement	8	105	

11. MISCELLANEOUS DATA
Yield Test: 3 Hrs. at 7 GPM
Depth from surface to normal water level 240 Ft.
Depth of water level when pumping 265 Ft. Stabilized Yes No
Well construction completed on 10-31-1979
Well is terminated 10 inches above below final grade
Well disinfected upon completion Yes No
Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 11-13-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address R2 Box 4 Boscobel, Wis., 53805

878