

AUG 12 1982

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Scott Name

2. LOCATION NE SE Section 20 Township 9N Range 3W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
 OR - Grid or Street No. Street or Road Name ADDRESS Rt. 2  
 AND - If available subdivision name, lot & block No. POST OFFICE Boscobel WI ZIP CODE 53805

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
C.I.	Other	C.I.	C.I. Sewer Other Sewer	C.I.	Other
C.I. <u>N/A</u>		C.I. <u>N/A</u>		C.I. <u>N/A</u>	

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	C.I. Other				Seepage Pit Seepage Bed Seepage Trench	
C.I. <u>N/A</u>		C.I. <u>N/A</u>		C.I. <u>N/A</u>		C.I. <u>N/A</u>		

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								
		C.I. <u>N/A</u>		C.I. <u>N/A</u>		C.I. <u>N/A</u>		C.I. <u>N/A</u>		C.I. <u>N/A</u>	

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	52	6	52	80	limestone	Surface	48
						hard shalestone	48	80

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	A-53 18.97 <sup>10</sup> / <sub>4</sub> +	Sumpton Pipe & Julie Pitless adapter	Surface	52

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
Cement	8	52

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Rotary-hammer & air  Reverse Rotary  Jetting with  Air  Water

Well construction completed on 5-18 1981

Well is terminated 15 inches  above  below final grade

Depth from surface to normal water level 60 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 62 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 7-26 1982

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Phil Capron Registered Well Driller Business Name and Complete Mailing Address Kenneth Capron & Son, Inc. Rt. 2 Box 4 Boscobel, WI 53805