

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH
See Instructions on Reverse Side

RECEIVED
 NOV 6 1951
 SANITARY DIV.
 HEALTH DEPT.

1. County Crawford { Town
 Village
 City Honey Check one and give name

2. Location Petersburg Wisconsin
 Name of street and number of premise or Sec. Tn. and R. numbers

3. Owner or Agent Petersburg Consolidated
 Name of individual, partnership or firm

4. Mail Address Petersburg Wis. R-4W, T-10N
 Complete address required

5. From well to nearest: Building 18 ft; sewer ✓ ft; drain — ft; septic tank 1 ft;
 dry well or filter bed — ft; abandoned well — ft. 125 from toilets

6. Well is intended to supply water for: Human Consumption

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)
6"	0	88
	old well	

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind	From (ft.)	To (ft.)
4"	old wt. liner	0	78

9. GROUT:

Kind	From (ft.)	To (ft.)
Cement		

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
old well	0	88

11. MISCELLANEOUS DATA:
 Yield test: 10 Hrs. at 8 GPM.
 Depth from surface to water: 20 ft.
 Water-level when pumping: same ft.
 Water sample sent to laboratory at Madison
Sept 12 on 1951

Repair on old
 Construction of the well was completed on Sept 8 1950
 The well is terminated 16" inches
 above, below the permanent ground surface.
 Was the well disinfected upon completion?
 Yes yes No —
 Was the well sealed watertight upon completion?
 Yes yes No —
202 W. de Grande St
 Complete Mail Address
Boccodell Wis.

Signature H. W. Bartels
 Registered Well Driller
(Nov 1, 1951)