

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

APR 29 1977

WELL CONSTRUCTOR'S REPORT
Form 3300-15
Rev. 10-75

1. COUNTY <i>Crawford</i>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <i>Clayton</i>	
2. LOCATION 1/4 Section <i>SW</i> Section <i>1</i> Township <i>10N</i> Range <i>4W</i>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <i>Mallory Halverson</i>			ADDRESS <i>RFD</i>	
OR - Grid or Street No. Street Name		AND - If available subdivision name, lot & block No.			POST OFFICE <i>Soldiers Grove, Wis. 54655</i>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <i>15'</i>	Sanitary Bldg. Drain C.I. <i>25'</i> Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer	Storm Bldg. Drain C.I. Other
Street Sewer San. Storm	Other Sewers C.I. Other	Foundation Drain Connected to: Sewer Clearwater Dr.	Sewage Sump C.I. Other	Clearwater Sump	Septic Tank <i>60'</i>	Holding Tank
Privy	Pet Waste Pit	Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen	Animal Yard
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)	
5. Well is intended to supply water for <i>Country home</i>				9. FORMATIONS		
6. DRILLHOLE				Kind		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	From (ft.) To (ft.)
<i>6</i>	<i>0</i>	<i>100</i>				<i>loose sand</i> Surface <i>0</i> <i>60</i>
						<i>sandstone</i> <i>60</i> <i>100</i>
7. CASING, LINER, CURBING AND SCREEN						
Dia. (in.)	Material, Weight, Specification & Method of Assembly		From (ft.)	To (ft.)		
<i>6</i>	<i>new black steel P.E. 18.97</i>		<i>0</i>	<i>73</i>		
	<i>A-53</i>					
	<i>Pitless adaptor Valley Steel</i>					
8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED		
Kind				From (ft.) To (ft.)		
<i>loose sand</i>				Surface <i>0</i> <i>60</i>		
				<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-air w/drilling mud <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water		
11. MISCELLANEOUS DATA				Well construction completed on <i>4-6-</i> 19 <i>77</i>		
Yield Test: <i>3</i> Hrs. at <i>5</i> GPM				Well is terminated <i>10</i> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth from surface to normal water level <i>40</i> Ft.				Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <i>62</i> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <i>Madison</i> laboratory on <i>4-26-</i> 19 <i>77</i>						

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature *Kenneth Cospian* Registered Well Driller Complete Mail Address *Roscobel, Wis. 53805*
R3 Box 84