

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

JUL 24 1975

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION - 1/4 Section SE Section 1 Township 10N Range 4W 3. OWNER AT TIME OF DRILLING La Von Hanson

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block)

| | | | | | | | | |
|------------|---------------------|------------|------------------|------------------|----------------------------------|------------------------------|------------------------|------------------------|
| BUILDING | SANITARY SEWER C.I. | SEWER TILE | FLOOR DRAIN C.I. | FLOOR DRAIN TILE | FOUNDATION DRAIN SEWER CONNECTED | FOUNDATION DRAIN INDEPENDENT | WASTE WATER DRAIN C.I. | WASTE WATER DRAIN TILE |
| <u>10'</u> | <u>25'</u> | | | | | | <u>25'</u> | |

| | | | | | | | | | |
|------------------------|------------------------|-------------|-------|-------------|------------------|------|-------|----------------|-----------|
| CLEAR WATER DRAIN C.I. | CLEAR WATER DRAIN TILE | SEPTIC TANK | PRIVY | SEEPAGE PIT | ABSORPTION FIELD | BARN | SILLO | ABANDONED WELL | SINK HOLE |
| | | <u>50'</u> | | | <u>65'</u> | | | | |

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | 9. FORMATIONS Kind | From (ft.) | To (ft.) |
|------------|----------------|-----------|------------|------------|------------|------------------------|----------------|------------|
| <u>10</u> | <u>Surface</u> | <u>61</u> | <u>6</u> | <u>61</u> | <u>140</u> | <u>Clay shalestone</u> | <u>Surface</u> | <u>15</u> |
| | | | | | | <u>sandstone</u> | <u>15</u> | <u>90</u> |
| | | | | | | | <u>90</u> | <u>140</u> |

7. CASING, LINER, CURBING, AND SCREEN

| Dia. (in.) | Kind and Weight | From (ft.) | To (ft.) |
|------------|--|----------------|-----------|
| <u>6</u> | <u>new black steel plain end 18.97</u> | <u>Surface</u> | <u>61</u> |

8. GROUT OR OTHER SEALING MATERIAL

| Kind | From (ft.) | To (ft.) |
|---------------|----------------|-----------|
| <u>Clay</u> | <u>Surface</u> | <u>15</u> |
| <u>Cement</u> | <u>15</u> | <u>61</u> |

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 7-3-1975

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 5 GPM

Well is terminated, 12 inches above below final grade

Depth from surface to normal water level 70 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 72 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 7-21-1975

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Cospian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

COLIFORM TEST RESULT 886 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS

REV. 3-71