

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

OCT 15 1979
OCT 15 1979

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION ¼ Section SE Section 1 Township 10 N Range 4 W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Mark Lathrop

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wis., 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Dr. Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 75' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	80	6	80	120

9. FORMATIONS

Kind	From (ft.)	To (ft.)
soft sand & clay	Surface	40
soft shale stone	40	65
hard sandstone	65	120

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53 Keystone Pipe (Pitless adapter)	Surface	80

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drifting mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	8
Cement	8	80

Well construction completed on 9-27- 19 79

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 6 GPM

Depth from surface to normal water level 60 Ft.

Depth of water level when pumping 72 Ft. Stabilized Yes No

Well is terminated 12 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 10-9- 19 79

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Corpians Registered Well Driller Complete Mail Address Boscobel, Wis., R2 Box 4 53805