

WELL CONSTRUCTOR'S REPORT

Well-6

APR 22 1971

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
SE 1/4 of Sec. 2 T10N R14W

3. OWNER AT TIME OF DRILLING Robert Jorgensen

4. OWNER'S COMPLETE MAIL ADDRESS R2 Soldiers Grove, Wis., 54655

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C.I.	TILE
10'	20'					20'	

CLEAR WATER DRAIN C.I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		65'		80'					

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Country Home

7. DRILLHOLE						10 FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	40	6	40	120	Clay	Surface	20	
						loose rock & clay	20	30	
						hard shale	30	100	
						sandstone	100	120	

8. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	40

9. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	20
Cement	20	40

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Well construction completed on 2-23-1971

Well is terminated 12 inches above below final grade

Depth from surface to normal water level 62 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 68 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 4-19-1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Henneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boocohel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>889</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------