

JUL 24 1975

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Clayton

2. LOCATION - 1/4 Section NE Section 2 Township 10N Range 4W  
OR - Grid or street no. Street name  
3. OWNER AT TIME OF DRILLING Robert Rosemeyer  
ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Soldiers Grove Wis. 54655

4. Distance in feet from well to nearest:  
(Record answer in appropriate block)  
BUILDING C.I. 70' SANITARY SEWER TILE C.I. 50' FLOOR DRAIN C.I. TILE FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT WASTE WATER DRAIN C.I. TILE  
CLEAR WATER DRAIN C.I. TILE SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE  
70' 85' 60'

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE  
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)  
6 Surface 100  
9. FORMATIONS Kind From (ft.) To (ft.)  
loose sand Surface 60  
sandstone 60 100

7. CASING, LINER, CURBING, AND SCREEN  
Dia. (in.) Kind and Weight From (ft.) To (ft.)  
6 new black steel plain end 18.97 Surface 72

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)  
loose sand Surface 60  
10. TYPE OF DRILLING MACHINE USED  
 Cable Tool  Direct Rotary  Reverse Rotary  
 Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water  
Well construction completed on 7-5- 1975

11. MISCELLANEOUS DATA  
Yield test: 3 Hrs. at 5 GPM  
Well is terminated 10 inches  above  below final grade  
Depth from surface to normal water level 70 ft. Well disinfected upon completion  Yes  No  
Depth to water level when pumping 72 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 7-21- 1975

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coryn Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

COLIFORM TEST RESULT 891 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS  
REV. 3-71