

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

SEP 25 1975

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION - 1/4 Section NE Section 11 Township 10 N Range 4 W
OR - Grid or street no. Street name
3. OWNER AT TIME OF DRILLING Mr. Jerome Blaschke
ADDRESS RFL

AND - If available subdivision name, lot & block no. POST OFFICE Soldiers Grove, Wis., 54655

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
<u>10'</u>	<u>25'</u>	<u>25'</u>				

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		<u>65'</u>			<u>70'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>54</u>	<u>6</u>	<u>54</u>	<u>100</u>	<u>Clay & stone sandstone</u>	<u>Surface</u>	<u>15</u>
							<u>15</u>	<u>25</u>
						<u>shalestone</u>	<u>25</u>	<u>90</u>
						<u>sandstone</u>	<u>90</u>	<u>100</u>

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>54</u>

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>drill cuttings</u>	<u>Surface</u>	<u>8</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>8</u>	<u>54</u>	Well construction completed on <u>9-5-1975</u>		

11. MISCELLANEOUS DATA		Well is terminated		Well disinfected upon completion		Well sealed watertight upon completion	
Yield test:	<u>3 Hrs. at</u>	<u>6 GPM</u>	<u>8 inches</u>	<input checked="" type="checkbox"/> above	<input type="checkbox"/> below	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Depth from surface to normal water level	<u>60</u>	ft.				<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Depth to water level when pumping	<u>62</u>	ft.				<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No

Water sample sent to Madison laboratory on: 9-22-1975

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT <u>898</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
---------------------------------	---------------	---------------	-----------	---------