

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name AUG 8 1986
Bredport
 2. LOCATION NW 1/4 NE 1/4 Section 5 Township 6N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
Mike Steiner
 OR - Grid or Street No. Street or Road Name ADDRESS R.R.

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien ZIP CODE 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30'
 Sanitary Bldg. Drain: C.I. Other
 Sanitary Bldg. Sewer: C.I. Other
 Floor Drain Connected To: C.I. Sewer Other Sewer
 Storm Bldg. Drain: C.I. Other
 Storm Bldg. Sewer: C.I. Other

Street Sewer: San. Storm
 Other Sewers: C.I. Other
 Foundation Drain Connected to: Sewer Sewage Sump
 Clearwater Dr. Clearwater Sump
 Sewage Sump: C.I. Other
 Clearwater Sump: C.I. Other
 Clearwater Sump: C.I. Other
 Sewage Sump: C.I. Other
 Holding Tank: 90'
 Sewage Absorption Unit: Seepage Pit Seepage Bed 180' Seepage Trench
 Manure Hopper or Retention or Pneumatic Tank

Privy: Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank
 Subsurface Pumproom: Nonconforming Existing
 Barn Gutter
 Animal Barn Pen
 Animal Yard
 Silo With Pit
 Glass Lined Storage Facility
 Silo w/o Pit
 Earthen Silage Storage Trench Or Pit
 Earthen Manure Basin

Temporary Manure Stack or Platform
 Watertight Liquid Manure Tank or Basin
 Manure Pressure Pipe
 Subsurface Gasoline or Oil Tank
 Waste Pond or Land Disposal Unit (Specify Type)
 Manure Storage Basin: Concrete Floor Only Concrete Floor and Partial Concrete Walls
 Other (Describe)

5. Well is intended to supply water for: Private 9. FORMATIONS:

Kind	From (ft.)	To (ft.)
<u>Loose sand & gravel</u>	<u>Surface</u>	<u>72</u>
<u>Lime rock</u>	<u>72</u>	<u>84</u>

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>73</u>			
<u>6</u>	<u>73</u>	<u>80</u>			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6</u>	<u>New Black Steel</u>	<u>Surface</u>	<u>73</u>
	<u>Plain End</u>		
	<u>KHC 280W</u>		
	<u>6x21 #18-97</u>		
	<u>ASTM A120 dt.</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Pitless Adaptor</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>73</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 8-2 19 86

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 8 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 9 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 20 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to MADISON laboratory on 8-6 19 86

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Michael D. Bein Registered Well Driller Business Name and Complete Mailing Address CORDIAN Well Drilling
R.R. 2 Boscobel WI 53825