

DEC 27 1977

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION 1/4 Section SW Section 12 Township 10 N Range 4 W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Donald L. Olson

OR - Grid or Street No. Street Name ADDRESS R 2 Box 33A

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) 30'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer San. Other Sewers Storm Foundation Drain Connected to: 12.5' Sewage Sump 100' Clearwater Sump 100' Septic Tank 100' Holding Tank 100' Sewage Absorption Unit 12.5'

San. Storm C.I. Other Sewer Clearwater Dr. Sewage Sump Clearwater Sump C.I. Other

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen 110' Animal Yard 160' Silo With Pit 160' Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>169</u>	<u>6</u>	<u>169</u>	<u>315</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>60</u>
<u>limestone</u>	<u>60</u>	<u>200</u>
<u>hard shalestone</u>	<u>200</u>	<u>220</u>
<u>sandstone</u>	<u>220</u>	<u>315</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>169</u>
	<u>Valley Steel Pitless adaptor</u>		

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-air w/drilling mud Rotary-w/drilling mud Rotary-hammer w/drilling mud & air Reverse Rotary Jetting with Air Water

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>169</u>

Well construction completed on Dec 5 - 1977

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 5 GPM

Depth from surface to normal water level 230 Ft.

Depth of water level when pumping 238 Ft. Stabilized Yes No

Well is terminated 10 inches above final grade below

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Dec 20 - 1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Corpian Registered Well Driller Complete Mail Address Boscobel, Wis. R3 Box 84 53805