

JUL 6 1976

State of Wisconsin  
Department of Natural Resources  
Box 450  
Madison, Wisconsin 53701

JUN 3 1976

NOTE:  
White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
Form 3300-15  
Rev. 10-75

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Clayton

2. LOCATION 1/4 Section SE Section 14 Township 10 N Range 4 W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
ADDRESS William F. Meyer  
R 7 D 2  
POST OFFICE Gay Mills, Wis., 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
San. Storm	C.I. Other	Sewer	C.I. Other				Seepage Pit Seepage Bed Seepage Trench

Privy  Pet Waste Pit  Pit: Nonconforming Existing  Well  Pump  Tank  Subsurface Pumproom  Nonconforming Existing  Barn Gutter  Animal Barn Pen  Animal Yard  Silo With Pit  Glass Lined Storage Facility  Silo w/o Pit  Earthen Silage Storage Trench Or Pit

Temporary Manure Stack  Watertight Liquid Manure Tank  Solid Manure Storage Structure  Subsurface Gasoline or Oil Tank  Waste Pond or Land Disposal Unit (Specify Type) holding pond - 10ft. Other (Give Description)

5. Well is intended to supply water for: apple trees

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	82	6	82	500	Clay	Surface	25
						broken limestone	25	60
						limestone	60	190
						sandstone	190	270
						hard shalestone	270	460
						sandstone	460	500

7. CASING, LINER, CURBING AND SCREEN  
Material, Weight, Specification & Method of Assembly

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	82

new black steel plain end 18.97 A-53  
Valley Steel

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Cement</u>	Surface	82

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on 5-10-1976

11. MISCELLANEOUS DATA

Yield Test: 15 Hrs. at 28 GPM Well is terminated 13 inches  above final grade  below

Depth from surface to normal water level 400 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 420 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 6-1-1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address Boscobel, Wis., 53805  
R3 Box 84